
TERRA DX 11 HCUA

MONOVALENT HEATING SYSTEM WITH GROUND AS HEAT SOURCE

ORDER NUMBER: 277030

SERIES: M2 TF MAX. 65 °C



APPLIANCE DATA

| Dimensions HxWxD | [mm] | 1285x600x681 | |
|----------------------|--------|------------------|--|
| Hydraulic connection | [inch] | 1 1/4" | |
| Weight | [kg] | 190 | |
| Casing colour | | White/anthracite | |

SPECIFICATION

| Phases/nominal voltage/frequency | [~]/[V]/[Hz] | 3/400/50 |
|--|--------------|---------------|
| Output factor cos φ | | 0,70 |
| Fuse protection (tripping curve "C") | [A] | 10 |
| Max. operating current | [A] | 8,00 |
| Max. starting current/max. with soft start | [A] | 41.00 / 20.50 |
| Sound power level/sound pressure level (at 1 m distance) | [dBA] | 50.10 / 42.10 |

HEATING MODE PERFORMANCE FIGURES (to EN 14511)

| Standard point E4/W35 | | |
|---|----------|-------------|
| Heating output | [kW] | 12,10 |
| Total power consumption / operating current | [kW]/[A] | 2.35 / 4.70 |
| COP | | 5,10 |

Operating point E-1/W35

| Heating output | [kW] | 10,10 |
|---|----------|-------------|
| Total power consumption / operating current | [kW]/[A] | 2.25 / 4.50 |
| СОР | | 4,60 |

Operating point E0/W50

| Heating output | [kW] | 9,00 |
|---|----------|-------------|
| Total power consumption / operating current | [kW]/[A] | 3.00 / 6.00 |
| COP | | 3,00 |

Operating point E0/W60

| Heating output | [kW] | 8,90 |
|---|----------|-------------|
| Total power consumption / operating current | [kW]/[A] | 3.80 / 7.80 |
| COP | | 2,30 |

CONDENSER

| Туре | | Plate heat exchanger |
|---|----------|---------------------------|
| Material | | Stainless steel 1.4301 |
| Max. refrigerant operating pressure | [bar] | 30 |
| Max. heat transfer medium operating pressure | [bar] | 6 |
| Heat transfer medium temperature differential | [K] | 5 |
| Application range | [°C] | 65 |
| Heat transfer medium | | Water |
| Test pressure | [bar] | 45 |
| Heat transfer medium flow rate | [m³/h] | 2,20 |
| Internal pressure differential | [mbar] | 324 |
| Flow meter (FM) | Internal | Installed as |
| Circulation pump heat sink (WNA) | Internal | Yonos Para HPS 25/7.5 |
| Residual head I WNA external | [mbar] | 211 |
| | | |

REFRIGERANT CIRCUIT

| Refrigerant | | R407C |
|------------------------------|------|---------|
| Refrigerant charge (from-to) | [kg] | 4,8-8,0 |

COMPRESSOR

| Туре | | Scroll |
|-------------------|----------|----------|
| Output levels | | 1 |
| Speed | [rpm] | 2900 |
| Voltage/frequency | [V]/[Hz] | 400 / 50 |

EVAPORATOR

| Туре | | Tube evaporator |
|-------------------------------------|-------|---|
| No. of circuits (recommended) | [pce] | (5*) 7 |
| No. of circuits (max.) | [pce] | 9 |
| Length per circuit | [m] | 75 |
| Material | | Copper / seamless PE outer casing |
| Max. refrigerant operating pressure | [bar] | 30 |

| Hydraulic | | Electric immersion heater | | 3-way switching module | |
|-----------|----------|---------------------------|----------|------------------------|---|
| version | Internal | external | Internal | external | |
| M2-1 | M4-1 | x | | x | |
| M2-2 | M4-2 | | × | x | |
| M2-3 | M4-3 | х | | | x |
| M2-4 | M4-4 | | × | | x |

^{*}Number of circuits possible for optimum soil conditions: cohesive soil/moist or better at max. 1800 h/a













The geothermal collectors O-Tube Pro are filled at the factory with nitrogen and each have a leakage indicator, which enables simple leakage monitoring during routing right up to the checks prior to commissioning. A collector array may not be built on and must be laid with a minimum clearance of 1.5 m to building components and property boundaries. The minimum spacing for collector pipes is 0.5 m. A routing plan of the individual collector circuits based on the actual routing is required for com-



missioning. The individual collector pipe ends of the collector circuits must be labelled.

RECOMMENDED ACCESSORIES

| | Order no./type | Description | Pressure loss |
|--|--------------------|--------------------------|---------------------------------|
| Heat pump separating cylinders | min. PU500 | 30 l/kW at G-1/W50 | - |
| DHW tank | min. SP300/SP350 | 30 I/kW at E0/W50 | - |
| External plate heat exchanger (DHW heating) | 911251 PHE 2007 | Prim.: 1" Sec.: 1" | Prim.: 77 mbar Sec.: 26 mbar |
| 3-way switching module internal | 980196 | - | - |
| 3-way switching module external | 290229 | DN32 (1 1/4"). kvs 16 | 19 mbar |
| Electric immersion heater internal | 980197 | 8.8 kW (2.9 / 2.9 / 2.9) | - |
| External electric immersion heater (heat pump buffer tank) | 922508 | 6 kW | - |
| Copper geothermal collector (O-Tube Pro) | 913209 | 75 m per unit | - |

REQUIRED

EXTRACTION SURFACE

| Basic cooling capacity (at E4/W35) | [kW] | 9.8 |
|--|------|-----|
| Extraction surface (at 1800 h/a) | [m²] | 392 |
| Extraction surface (at 2400 h/a) | [m²] | 490 |
| Max. connection length to collection shaft | [lm] | 20 |

CONDITIONS IN ACC. WITH VDI 4640 OR ÖWAV 207


| Soil conditions | Max. spec. extraction capacity at 1800 h/a | Max. spec. extraction capacity at 2400 h/a |
|---------------------------------------|---|---|
| Dry, non-cohesive soil | 10 W/m ² and 5 W/lm | 8 W/m² and 4 W/lm |
| Cohesive soil, moist | 20-30 W/m² and 15 W/Im | 16-24 W/m² and 12 W/lm |
| Water-saturated soil, sand/ gravel | 40 W/m ² and 20 W/lm | 32 W/m² and 16 W/lm |

PRODUCT DATA ErP: TERRA DX 11 HCUA

| | | COLDER | MEAN | HOTTER |
|--------------------|-------|--------|------|--------|
| LOW TEMPERATURE | A++ | | 35°C | |
| ηs | | 224 | 216 | 215 |
| Energy consumption | [kWh] | 5145 | 4472 | 2901 |
| P rated | [kW] | 12 | 12 | 12 |
| SCOP | | 5,80 | 5,59 | 5,57 |
| MEDIUM TEMPERATURE | A++ | | 55°C | |
| ηs | | 148 | 143 | 143 |
| Energy consumption | [kWh] | 6697 | 5786 | 3761 |
| P rated | [kW] | 11 | 11 | 11 |
| SCOP | | 3,90 | 3,78 | 3,77 |

| DHW | Α | | SP300 | |
|--------------------|-------|--------|---------|------|
| ηWH | | 95 | 95 | 95 |
| Energy consumption | [kWh] | 1499 | 1499 | 1499 |
| Draw-off profile | | | XL | |
| Tank losses | [W] | | 94 | |
| | | indoor | outdoor | |

| | | indoor | outdoor | |
|------------------------------|------------------|--------|-----------------------------|-----|
| Sound power level | [dBA] | 50,1 | - | |
| Controller class with room r | emote control | VII | Controller contribution [%] | 3,5 |
| Controller class without roo | m remote control | III | Controller contribution [%] | 1,5 |



1 Concrete ring (D = min. 1500 mm) Shaft depth min. 2000 mm

2 Access (D = min. 800 mm)

- 4 Collector pipes
- 7 Pipe liner to building (D = min. 150 mm)

PERFORMANCE CURVES TERRA DX 11 HCUA

